


THIRD ANGLE
PROJECTION



6 kW WIND TURBINE 10m MAST FOUNDATION

Drawing AMP061 Issue A dated 14 Nov 08

General Assembly Scale 1 : 15

Reinforcement schedule:

Use A252 mesh throughout (200 x 200 x 8 dia wire)
to BS 4483:2005

Reinforcement cover 100 throughout

2 off 2200 square; 2 off 2000 square; 4 off bent and interleaved
as shown, size before bending 1850 x 914

Total weight of mesh 97 kg approx.

NOTES: 1. Design max overturning moment at base = 82 kNm


2. Total weight concrete ex reinf. = 7.9 t approx.

Required minimum soil bearing pressure is 50 kN/sq m.


3. Concrete specification designated RC30 or better to BS 8500-1:2002

4. Concrete may be poured into the excavated hole without shuttering if soil
conditions permit. Ensure base is well compacted before pouring.

5. Nuts on base flange to be tightened after curing to 530 Nm torque.



MESH INDICATIVE ONLY



FOUNDATION FOR 10m MAST TO ASMB00258 FOR AMPAIR 6kW WIND TURBINE
E-mail instruction 040908 refers

Wind loadings to IEC 61400-2
(Draft International standard, Ed2 2006)

For Class III SWT (Table 1)

Basic wind speed V_{ref}

50-year wind (Eqn 10)

V_{e50}

Coefficient C_f from Table 3

ρ from IEC

Design wind pressure p_{net}

$$V_{ref} := 37.5 \cdot \frac{m}{s}$$

$$V_{e50} := 1.4 \cdot V_{ref}$$

$$C_f := 2$$

$$\rho := 1.225 \cdot \frac{kg}{m^3}$$

$$p_{net} := \frac{C_f}{2} \cdot \rho \cdot V_{e50}^2 \quad p_{net} = 3.376 \times 10^3 \text{ Pa}$$

Resulting forces & moments at base:

Turbine effective frontal area in high wind A_{proj}

$$A_{proj} := 18000 \cdot cm^2$$

Mast height l_{mst} 10m

C/l turbine height above mast top $clht$ 300mm

Moment due to turbine M_t

Mast average width w_{mst} 170mm

$$F_{rot} := p_{net} \cdot A_{proj} \quad F_{rot} = 6.078 \text{ kN}$$

$$l_{mst} := 10 \cdot m \quad clht := 0.3 \cdot m \quad tht := l_{mst} + clht$$

$$M_t := F_{rot} \cdot tht \quad M_t = 62.6 \text{ kN} \cdot m$$

$$w_{mst} := 0.17 \cdot m$$

Moment due to mast M_{mst} , assuming
 wind speed proportional to height, zero on ground

$$M_{mst} := p_{net} \cdot w_{mst} \cdot \frac{l_{mst}^2}{3} \quad M_{mst} = 19.1 \text{ kN} \cdot m$$

Total overturning moment M_{ov}

$$M_{ov} := M_{mst} + M_t \quad M_{ov} = 81.7 \text{ kN} \cdot m$$

Foundation design

$$dpth := 0.6 \cdot m \quad density := 2300 \cdot \frac{kg}{m^3} \quad lsqu := 2.4 \cdot m \quad Wt := lsqu^2 \cdot dpth \cdot density \quad Wt = 7.949 \text{ tonne}$$

$$M_{res} := Wt \cdot g \cdot \frac{lsqu}{2} \quad M_{res} = 93.5 \text{ kN} \cdot m \quad \text{OK against overturning.}$$


$$BM_{max} := \frac{M_{ov}}{2} \quad \text{Roark Table 3-3(e)} \quad Meshload := \frac{BM_{max}}{dpth - 0.2 \cdot m} \quad Meshload = 102.2 \text{ kN}$$

Mesh specified is 2 x A 252, each layer safe loading 57845 N per m wide, ref BS 4483

$Meshres := 57845 \cdot N \cdot 2$ $Meshres = 115.7 \text{ kN}$ **OK for mesh strength, load conc'd on central 1m**

$$boltsep := 0.48 \cdot m \quad T_{perbolt} := \frac{M_{ov}}{boltsep \cdot 2} \quad T_{perbolt} = 85.1 \text{ kN}$$

SWL for M30 6.6 grade is 183 kN. Rebar is equivalent. **OK for hold down bolts.**



6 kW WIND TURBINE 15m MAST FOUNDATION
Drawing AMP060 Issue B dated 14 Nov 08
General Assembly Scale 1 : 15


Reinforcement schedule:

Use A393 mesh throughout (200 x 200 x 10 dia wire)
 to BS 4483:2005


Reinforcement cover 100 throughout
 2 off 2800 square; 2 off 2600 square; 4 off bent and interleaved
 as shown, size before bending 2450 x 914
 Total weight of mesh 235 kg approx.

- NOTES:** 1. Design max overturning moment at base = 136 kNm
 2. Total weight concrete ex reinf. = 12.4 t approx.
 Required minimum soil bearing pressure is 50 kN/sq m.
 3. Concrete specification designated RC30 or better to BS 8500-1:2002
 4. Concrete may be poured into the excavated hole without shuttering if soil
 conditions permit. Ensure base is well compacted before pouring.
 5. Nuts on base flange to be tightened after curing to 530 Nm torque.

SECTION AA OR BB



MESH INDICATIVE ONLY



FOUNDATION FOR 15m MAST TO ASMB00258 FOR AMPAIR 6kW WIND TURBINE
E-mail instruction 040908 refers

Wind loadings to IEC 61400-2
(Draft International standard, Ed2 2006)

For Class III SWT (Table 1)

Basic wind speed V_{ref}

$$V_{ref} := 37.5 \cdot \frac{m}{s}$$

50-year wind (Eqn 10)

$$V_{e50} := 1.4 \cdot V_{ref}$$

V_{e50}

Coefficient C_f from Table 3

$$C_f := 2$$

ρ from IEC

$$\rho := 1.225 \cdot \frac{kg}{m^3}$$

Design wind pressure p_{net}

$$p_{net} := \frac{C_f}{2} \cdot \rho \cdot V_{e50}^2 \quad p_{net} = 3.376 \times 10^3 \text{ Pa}$$

Resulting forces & moments at base:

Turbine effective frontal area in high wind A_{proj}

$$A_{proj} := 18000 \cdot cm^2$$

Mast height l_{mst} 15m

$$F_{rot} := p_{net} \cdot A_{proj} \quad F_{rot} = 6.078 \cdot kN$$

C/l turbine height above mast top $clht$ 300mm

$$l_{mst} := 15 \cdot m \quad clht := 0.3 \cdot m \quad tht := l_{mst} + clht$$

Moment due to turbine M_t

$$M_t := F_{rot} \cdot tht \quad M_t = 93 \cdot kN \cdot m$$

Mast average width w_{mst} 170mm

$$w_{mst} := 0.17 \cdot m$$

Moment due to mast M_{mst}

$$M_{mst} := p_{net} \cdot w_{mst} \cdot \frac{l_{mst}^2}{3} \quad M_{mst} = 43 \cdot kN \cdot m$$

Total overturning moment M_{ov}

$$M_{ov} := M_{mst} + M_t \quad M_{ov} = 136 \cdot kN \cdot m$$

Foundation design

$d_{pth} := 0.6 \cdot m$ $density := 2300 \cdot \frac{kg}{m^3}$

$lsqu := 3 \cdot m$ $Wt := lsqu^2 \cdot d_{pth} \cdot density$ $Wt = 12.42 \cdot tonne$

$$M_{res} := Wt \cdot g \cdot \frac{lsqu}{2}$$

$$M_{res} = 182.7 \cdot kN \cdot m$$

OK against overturning.

$$BM_{max} := \frac{M_{ov}}{2}$$

$$\text{Roark Table 3-3(e)} \quad Meshload := \frac{BM_{max}}{d_{pth} - 0.2 \cdot m} \quad Meshload = 170 \cdot kN$$

Mesh specified is 2 x A 393, each layer safe loading 90275 N per m wide, ref BS 4483

$Meshres := 90275 \cdot N \cdot 2$ $Meshres = 180.6 \cdot kN$ **OK for mesh strength, load conc'd on central 1m**

$boltsep := 0.48 \cdot m$

$$T_{perbolt} := \frac{M_{ov}}{boltsep \cdot 2}$$

$$T_{perbolt} = 141.7 \cdot kN$$

SWL for M30 6.6 grade is 183 kN. Rebar is equivalent. **OK for hold down bolts.**